



ADDENDUM NUMBER ONE

July 13, 2023

**IFB#23-912-34
THREE GENERATORS FOR GUSTE HIGH RISE**

THIS ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING IN THE REFERENCED REQUEST FOR QUOTES.

Question:

I see on generator I, there is a request for Two (2) Automatic Transfer Switches:

- (1) 100 AMP 120/208 3-phase 4- wire ATS
- (1) 200 AMP 120/208 3-phase 4-wire ATS.

But I do not see any additional ATS associated with the other two generators, are these the only 2 ATS(s) needed for the quote?

Answer: The scope of work only calls for two ATS.

Quotes must be received by the Housing Authority of New Orleans (HANO) in the Office of Procurement and Contracts by 2:00 p.m., local time on Friday, August 4, 2023. All terms and conditions shall remain as stated in the original Request for Quotes. **All addenda must be acknowledged.**

END OF ADDENDUM NUMBER ONE