



ADDENDUM NUMBER ONE

January 13, 2021

**REQUEST FOR QUOTES #21-912-10
REPAIRS TO AREA LIGHTING AND ELECTRICAL EQUIPMENT AT THE GUSTE
HIGH RISE COMMUNITY**

**THIS ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING
INTO THE REFERENCED REQUEST FOR QUOTES**

ITEM #1 QUESTIONS ASKED DURING PRE-BID CONFERENCE

Q1: Are the panels in all of the rooms UL rated?

A1: Respondents shall assume that the electrical panels have UL labels.

Q2: Are the panels to be replaced?

A2: No. Refer to drawings.

Q3: Are we taking out the old panels and putting in new panels?

A3: No. Refer to drawings.

**Q4: Are we only putting in the cover panels that are required for the
panels that are already there?**

A4: Yes. Refer to drawings.

Q5: What should we know about the starter?

A5: A direct replacement for the existing starter is required. Refer to drawings.

Q6: Are we required to use Eaton Engineering Services?

A6: Yes.

Q7: What fixtures are to be replaced?

A7: The parking lot and gallery fixtures are to be replaced. Refer to drawings.

Q8: Are we to use LED?

A8: Yes, LED is to be used.

ITEM #2 PRE-BID CONFERENCE SIGN IN SHEET

INSERT: Add the "Pre-Bid Conference Sign-In Sheet" to the RFQu, as attached.

Bids must be received by the Housing Authority of New Orleans (HANO) in the Department of Procurement and Contracts by 2:00 P.M. CST on Friday, January 15, 2021. All terms and conditions shall remain as stated in the original Invitation for Bids. All addenda must be acknowledged.

END OF ADDENDUM NUMBER ONE